

Certificate of Conformity

No. ESY 127292 0004 Rev. 00

Holder of Certificate: **Sunshare Technology Co., Ltd.**

2nd Floor, Building A
No. 2999 Jiyin Avenue, Jiangning District
211100 Nanjing City, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Converter
(PV Inverter)**

Model(s): **SR-C800EU**

Parameters: See page 2

Applicable standards: VDE-AR-N 4105:2018
DIN VDE V 0124-100 (VDE V 0124-100):2020

This Certificate of Conformity confirms the compliance with the above listed standards on a voluntary basis. It refers only to the sample submitted to TÜV SÜD Product Service GmbH and does not certify the quality or safety of the serial products. It was issued according to TÜV SÜD Product Service certification program Photovoltaics and Grid Integration. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290243106001

Date, 2024-11-12



(Billy Qiu)

Certificate of Conformity

No. ESY 127292 0004 Rev. 00

Parameters:

Model	SR-C800EU
PV terminal parameters	
Maximum PV voltage [V _{DC}]	60
Rated voltage [V _{DC}]	40
MPPT voltage range [V _{DC}]	22-55
Maximum input current [A _{DC}]	28
I _{sc} PV [A _{DC}]	32
MPPT tracker number	1
Maximum input power [W]	800
Grid terminal output parameters	
Rated output voltage [V _{AC}]	1P+N+PE, 230
Rated output frequency [Hz]	50
Rated output current [A _{AC}]	3.48
Maximum continuous output current [A _{AC}]	3.48
Rated output active power [W]	800
Maximum output active power P _{E_{max}} [W]	800
Maximum output apparent power S _{E_{max}} [VA]	800
Power factor range	0.95 inductive(under-excited) to 0.95 capacitive(over-excited)

Certificate of Conformity

No. ESY 127292 0004 Rev. 00

E.4 Unit certificate

Unit certificate		
Manufacturer	Sunshare Technology Co., Ltd.	
Power generation unit type	[Micro Inverter]: <u>SR-C800EU</u>	
Assessment values	max. active power $P_{E_{max}}$	<u>800 W(SR-C800EU)</u>
	max. apparent power $S_{E_{max}}$	<u>800 VA(SR-C800EU)</u>
	Rated voltage	<u>1P+N+PE, 230 V_{AC}</u>
	Rated current (AC) I_r	<u>3.48 A(SR-C800EU)</u>
	Initial short-circuit AC current I''_k	<u>3.48 A(SR-C800EU)</u>
Network connection rule	VDE-AR-N 4105:2018-11 “Generators connected to the low-voltage distribution network” Technical minimum requirements for connection and parallel operation of power generation systems connected to the low-voltage network	
Test requirement	DIN VDE V 0124-100 (VDE V 0124-100):2020-06 “Network integration of power generation systems – Low voltage” Test requirements for power generation units intended for connection to and parallel operation on the low-voltage network	
Test report	<u>64.290.24.31060.01</u> from <u>2024-10-16</u>	
The above designated power generation unit meets the requirements of VDE-AR-N 4105:2018-11.		

Certificate of Conformity

No. ESY 127292 0004 Rev. 00

E.5 Test report "Network interactions" for power generation units with an input current > 75 A

Extract of the test report for power generation units "Determination of electrical properties"	
System manufacturer:	<u>Sunshare Technology Co., Ltd.</u> <u>2nd Floor, Building A, No. 2999 Jiyin Avenue, Jiangning District,</u> <u>211100 Nanjing City, Jiangsu Province, PEOPLE'S REPUBLIC OF</u> <u>CHINA</u>
Manufacturer indications:	Type of system Micro Inverter for PV systems
	Max. active power $P_{E_{max}}$ <u>800 W(SR-C800EU)</u>
	Rated voltage <u>1P+N+PE, 230 V_{AC}</u>
Measurement period:	<u>From 2024-07-22 to 2024-10-16</u>

Rapid voltage change	
Model	<u>SR-C800EU</u>
Connection without provisions (regarding the primary energy carrier)	$K_i=0.51$
Most adverse case when switching between generator levels	$K_i=0.51$
Connection at nominal conditions (of the primary energy carrier)	$K_i=1.01$
Disconnection at rated power	$K_i=1.01$
Worst value of all switching operations	$K_{i_{max}}=1.01$

Flicker (SR-C800EU)					
Network impedance angle Ψ_k	30°	50°	70°	85°	32°
Coefficient of system flicker C_ψ (Maximum)					
L1	--	--	--	--	0.8448
L2	--	--	--	--	--
L3	--	--	--	--	--
Remark: The ratio of $S_{k,fic}/S_n$ used for the analysis: 33 during the test.					

Certificate of Conformity

No. ESY 127292 0004 Rev. 00

Harmonics (≤ 16 A) (SR-C800EU)												
Active power P/Pn[%]	0	10	20	30	40	50	60	70	80	90	100	Limit value
Ordinal number	A	A	A	A	A	A	A	A	A	A	A	A
2	0.001	0.002	0.003	0.004	0.005	0.006	0.007	0.008	0.010	0.009	0.013	1.08
3	0.000	0.005	0.009	0.015	0.020	0.025	0.028	0.033	0.039	0.040	0.041	2.30
4	0.001	0.001	0.002	0.003	0.003	0.004	0.005	0.006	0.008	0.006	0.006	0.43
5	0.001	0.004	0.006	0.011	0.015	0.018	0.021	0.024	0.025	0.020	0.017	1.14
6	0.000	0.001	0.001	0.002	0.003	0.003	0.004	0.005	0.003	0.004	0.005	0.30
7	0.001	0.003	0.005	0.009	0.012	0.015	0.017	0.019	0.025	0.023	0.023	0.77
8	0.000	0.001	0.001	0.002	0.003	0.003	0.004	0.004	0.004	0.004	0.005	0.23
9	0.001	0.003	0.004	0.008	0.010	0.013	0.014	0.017	0.018	0.015	0.013	0.40
10	0.001	0.001	0.001	0.002	0.003	0.003	0.004	0.004	0.003	0.004	0.004	0.18
11	0.001	0.002	0.004	0.007	0.010	0.012	0.013	0.016	0.018	0.016	0.017	0.33
12	0.000	0.001	0.001	0.002	0.003	0.003	0.004	0.004	0.003	0.004	0.004	0.15
13	0.001	0.002	0.004	0.006	0.009	0.011	0.012	0.014	0.018	0.015	0.011	0.21
14	0.000	0.001	0.001	0.002	0.002	0.003	0.004	0.004	0.003	0.003	0.005	0.13
15	0.001	0.002	0.003	0.006	0.008	0.010	0.012	0.014	0.014	0.012	0.012	0.15
16	0.001	0.001	0.001	0.002	0.002	0.003	0.004	0.004	0.003	0.003	0.005	0.12
17	0.001	0.002	0.003	0.006	0.008	0.010	0.012	0.014	0.020	0.017	0.012	0.13
18	0.000	0.001	0.001	0.002	0.002	0.003	0.004	0.004	0.003	0.004	0.005	0.10
19	0.001	0.002	0.004	0.007	0.009	0.011	0.013	0.015	0.015	0.013	0.009	0.12
20	0.001	0.001	0.001	0.002	0.002	0.003	0.004	0.004	0.003	0.004	0.005	0.09
21	0.001	0.003	0.004	0.008	0.010	0.013	0.016	0.018	0.025	0.022	0.014	0.11
22	0.001	0.001	0.001	0.002	0.003	0.003	0.004	0.004	0.003	0.004	0.005	0.08
23	0.001	0.003	0.005	0.009	0.012	0.015	0.018	0.021	0.023	0.021	0.013	0.10
24	0.001	0.001	0.001	0.002	0.003	0.003	0.004	0.004	0.004	0.004	0.005	0.08
25	0.001	0.004	0.006	0.010	0.014	0.017	0.021	0.024	0.030	0.029	0.021	0.09
26	0.001	0.001	0.001	0.002	0.003	0.003	0.004	0.004	0.004	0.004	0.005	0.07
27	0.001	0.004	0.006	0.011	0.015	0.019	0.022	0.026	0.030	0.028	0.021	0.08
28	0.001	0.001	0.001	0.002	0.003	0.003	0.004	0.004	0.004	0.004	0.005	0.07
29	0.001	0.004	0.007	0.012	0.015	0.019	0.023	0.027	0.033	0.032	0.025	0.08
30	0.001	0.001	0.001	0.002	0.003	0.003	0.004	0.005	0.004	0.005	0.005	0.06
31	0.001	0.004	0.007	0.012	0.015	0.019	0.023	0.027	0.031	0.030	0.025	0.07
32	0.001	0.001	0.001	0.002	0.003	0.003	0.004	0.005	0.004	0.005	0.005	0.06
33	0.001	0.004	0.007	0.011	0.015	0.019	0.023	0.026	0.031	0.031	0.027	0.07
34	0.001	0.001	0.001	0.002	0.003	0.004	0.004	0.005	0.005	0.005	0.006	0.05
35	0.001	0.004	0.007	0.011	0.014	0.018	0.022	0.025	0.028	0.030	0.027	0.06
36	0.001	0.001	0.001	0.002	0.003	0.004	0.005	0.005	0.005	0.005	0.006	0.05
37	0.001	0.003	0.006	0.010	0.013	0.017	0.020	0.023	0.026	0.030	0.027	0.06
38	0.001	0.001	0.002	0.003	0.003	0.004	0.005	0.006	0.005	0.006	0.006	0.05
39	0.001	0.003	0.006	0.009	0.012	0.016	0.019	0.022	0.024	0.028	0.027	0.06
40	0.001	0.001	0.002	0.003	0.003	0.004	0.005	0.006	0.006	0.006	0.006	0.05
THD	4.395	4.371	4.110	4.510	4.515	4.474	4.379	4.358	4.382	3.932	3.295	5%
Remark: 1. Iref=3.48 A. 2. Rsce=33.												

Certificate of Conformity

No. ESY 127292 0004 Rev. 00

E.6 Certificate of the network and system protection

Certificate of NS protection	
Manufacturer	<u>Sunshare Technology Co., Ltd.</u>
Type of NS protection	Integrated NS protection
Central NS protection	<input type="checkbox"/>
Integrated NS protection	<input checked="" type="checkbox"/> Assigned to power generation unit of type: <u>SR-C800EU</u>
Network connection rule	VDE-AR-N 4105:2018-11 “Generators connected to the low-voltage distribution network” Technical minimum requirements for connection and parallel operation of power generation systems connected to the low-voltage network
Test requirement	DIN VDE V 0124-100 (VDE V 0124-100):2020-06 “Network integration of power generation systems – Low voltage” Test requirements for power generation units intended for connection to and parallel operation on the low-voltage network
Test report	<u>64.290.24.31060.01</u> from <u>2024-10-16</u>
The network and system protection designated above meets the requirements of VDE-AR-N 4105:2018-11.	

Certificate of Conformity

No. ESY 127292 0004 Rev. 00

E.7 Requirements for the test report for the NS protection

Extract from test report for NS protection			
"Determination of electrical properties"			
NS protection test report			
Type of NS system:	Integrated NS protection	Other Manufacturer indications	
Software version:	8A		
Manufacturer:	Sunshare Technology Co., Ltd. 2nd Floor, Building A, No. 2999 Jiyin Avenue, Jiangning District, 211100 Nanjing City, Jiangsu Province, PEOPLE'S REPUBLIC OF CHINA		
Measuring period:	From 2024-07-31 to 2024-08-01		
	Inverter		
Protection function	Setting value	Tripping value	Tripping time NS protection*
Rise-in-voltage protection $U \gg$	$1.25 * U_n$	L1-N: 287.42V	L1-N: 189.46ms
Rise-in-voltage protection $U >$	$1.10 * U_n$	$1.10 * U_n$	ms**
Voltage drop protection $U <$	$0.8 * U_n$	L1-N: 184.21V	L1-N: 3000.02ms
Voltage drop protection $U \ll$	$0.45 * U_n$	L1-N: 103.49V	L1-N: 380.43ms
Frequency decrease protection $f <$	47.5 Hz	47.49Hz	170.30ms
Frequency increase protection $f >$	51.5 Hz	51.51Hz	191.59ms
*: The tripping time includes the period from the limit value violation U/f until disconnection of the integrated interface switch (sum of the tripping time of the NS protection plus the response time of the integrated interface switch). **: Verification disconnection time of moving 10-min-average value. Disconnecting time as below: 507.34s (L1-N from 600s@ U_n to 112% U_n) Continuous operation (L1-N from 600s@ U_n to 108% U_n) 309.36s (L1-N from 600s@106% U_n to 114% U_n)			
<input checked="" type="checkbox"/> as integrated NS protection			
Assigned to power generation unit type	<u>SR-C800EU</u>		
Integrated interface switch type	Series-connected relays for all phase conductors each Relay type: W35L-2AT-L2-DC12V		
Response time of interface switch for integrated NS protection	Release time: Max. 5 ms		
Verification of the entire functional chain "integrated NS protection – interface switch" has resulted in successful disconnection.	<input checked="" type="checkbox"/>		